

U.S. Department of Labor

Occupational Safety and Health Administration
8713 Airport Freeway
Suite 302
Fort Worth, TX 76180
Phone: 817-428-2470 Fax: 817-581-7723



Citation and Notification of Penalty

To:
Warnick Metal Building Erectors, Ltd.
and its successors
4018 Clay Avenue
Fort Worth, TX 76117

Inspection Number: 1051178
Inspection Date(s): 04/02/2015 - 04/16/2015
Issuance Date: 09/29/2015

Inspection Site:
191 U.S. Hwy 377
Argyle, TX 76226

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty **you either call to schedule an informal conference (see paragraph below) or** you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1051178
Inspection Date(s): 04/02/2015 - 04/16/2015
Issuance Date: 09/29/2015



Citation and Notification of Penalty

Company Name: Warnick Metal Building Erectors, Ltd.
Inspection Site: 191 U.S. Hwy 377, Argyle, TX 76226

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1926.754(a): The employer did not maintain structural stability at all times during the erection process.

At the Argyle High School, the employer failed to maintain structural stability during erection of the pre-engineered metal building, which collapsed exposing employees to struck by or crushed by hazards.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:
Proposed Penalty:

11/19/2015
\$7000.00



Jack A. Rector
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor

Occupational Safety and Health Administration
8713 Airport Freeway
Suite 302
Fort Worth, TX 76180
Phone: 817-428-2470 Fax: 817-581-7723



Citation and Notification of Penalty

To:
Northstar Builders Group, LLC
and its successors
270 N. Denton Tap Road
Suite 250
Coppell, TX 75019

Inspection Number: 1051231
Inspection Date(s): 04/02/2015 - 04/16/2015
Issuance Date: 09/29/2015

Inspection Site:
191 U.S. Hwy. 377
Argyle, TX 76226

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty **you either call to schedule an informal conference (see paragraph below) or** you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1051231
Inspection Date(s): 04/02/2015 - 04/16/2015
Issuance Date: 09/29/2015



Citation and Notification of Penalty

Company Name: Northstar Builders Group, LLC
Inspection Site: 191 U.S. Hwy. 377, Argyle, TX 76226

Citation 1 Item 1 Type of Violation: **Serious**


29 CFR 1926.754(a): The employer did not maintain structural stability at all times during the erection process.

At the Argyle High School, the employer failed to maintain structural stability during erection of the pre-engineered metal building, which collapsed exposing employees to struck by or crushed by hazards.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:
Proposed Penalty:

11/19/2015
\$7000.00



Jack A. Rector
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.