

Wisconsin communities exceeding health limits for radium

25 water systems have exceeded the maximum contaminant level of radium of 5 picocuries per liter (pCi/L) in the past two years

Contaminant	Measured Amount	Units	System Name	DNR Public Water Supply ID	Status of the Sampled Well	Sample date mm/dd/yyyy
RADIUM, (226 + 228)	8.6	PCI/L	TOMAH WATERWORKS	64202545	New, not yet in service	01/27/2016
RADIUM-226	5.95	PCI/L	TOMAH WATERWORKS	64202545	New, not yet in service	01/27/2016
RADIUM, (226 + 228)	6.88	PCI/L	ASHWAUBENON WATERWORKS	40504563	Active	03/17/2014
RADIUM-226	21.7	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	03/18/2015
RADIUM-228	23.2	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	03/18/2015
RADIUM-226	9.22	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	02/25/2015
RADIUM, (226 + 228)	6.93	PCI/L	ASHWAUBENON WATERWORKS	40504563	Active	03/17/2014
RADIUM-228	15.4	PCI/L	WAUKESHA WATER UTILITY	26802380	Active	06/17/2014
RADIUM, (226 + 228)	44.9	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	03/18/2015
RADIUM, (226 + 228)	13.61	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	02/25/2015
RADIUM-226	18.3	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	08/27/2014
RADIUM-228	22.1	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	08/27/2014
RADIUM, (226 + 228)	40.4	PCI/L	HOLLAND TN SANITARY DIST	40507269	Active	08/27/2014
RADIUM, (226 + 228)	5.626	PCI/L	GREEN BAY WATERWORKS	40503562	Active	05/19/2014
RADIUM, (226 + 228)	6.72	PCI/L	GREEN BAY WATERWORKS	40503562	Active	05/19/2014

[228\)](#)

RADIUM, (226 + 228)	10.87	PCI/L	GREEN BAY WATERWORKS	40503562	Active	05/19/2014
RADIUM, (226 + 228)	6.55	PCI/L	GREEN BAY WATERWORKS	40503562	Active	05/19/2014
RADIUM, (226 + 228)	9.76	PCI/L	CAMBRIDGE PLACE OF DELAFIELD	26863254	Active	05/07/2015
RADIUM-226	9.76	PCI/L	CAMBRIDGE PLACE OF DELAFIELD	26863254	Active	05/07/2015
RADIUM-226	8.55	PCI/L	GREEN BAY WATERWORKS	40503562	Active	05/19/2014
RADIUM, (226 + 228)	7.72	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	05/07/2014
RADIUM, (226 + 228)	7.12	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	05/07/2014
RADIUM, (226 + 228)	8.78	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	05/07/2014
RADIUM-226	5.51	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	05/07/2014
RADIUM, (226 + 228)	9.27	PCI/L	ALLOUEZ WATERWORKS	40504552	Active	07/15/2014
RADIUM-226	7.73	PCI/L	ALLOUEZ WATERWORKS	40504552	Active	07/15/2014
RADIUM, (226 + 228)	8.49	PCI/L	HOWARD WATERWORKS	40504684	Active	03/31/2014
RADIUM, (226 + 228)	10.37	PCI/L	BROOKFIELD HILLS	26802765	Active	05/14/2015
RADIUM-226	6.43	PCI/L	BROOKFIELD HILLS	26802765	Active	05/14/2015
RADIUM, (226 + 228)	7.25	PCI/L	SUSSEX VILLAGE HALL & WATER UTILITY	26802336	Active	05/20/2014
RADIUM, (226 + 228)	9.03	PCI/L	BURLINGTON WATERWORKS	25201770	Active	04/01/2014
RADIUM, (226 + 228)	7.46	PCI/L	BURLINGTON WATERWORKS	25201770	Active	04/01/2014
RADIUM, (226 + 228)	8.13	PCI/L	HOWARD WATERWORKS	40504684	Active	03/31/2014

RADIUM, (226 + 228)	9.4	PCI/L	JOHNSON CREEK WATERWORKS	12801074	Active	03/12/2014
RADIUM, (226 + 228)	6.73	PCI/L	LOMIRA WATERWORKS	11401511	Active	03/25/2014
RADIUM, (226 + 228)	6.84	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	06/01/2015
RADIUM, (226 + 228)	5.51	PCI/L	LOMIRA WATERWORKS	11401511	Active	05/27/2015
RADIUM, (226 + 228)	6.16	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	06/01/2015
RADIUM, (226 + 228)	6.56	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	06/01/2015
RADIUM, (226 + 228)	8.9	PCI/L	BROOKFIELD WATER UTILITY	26802534	Active	12/09/2014
RADIUM, (226 + 228)	18.76	PCI/L	WAUKESHA WATER UTILITY	26802380	Active	06/17/2014
RADIUM, (226 + 228)	5.61	PCI/L	BROWNSVILLE WATERWORKS	11401390	Active	05/07/2014
RADIUM, (226 + 228)	8.9	PCI/L	FRANKLIN WATER UTILITY	24105631	Permanently Abandoned	03/12/2014
RADIUM, (226 + 228)	6.56	PCI/L	FRANKLIN WATER UTILITY	24105631	Active	03/12/2014
RADIUM, (226 + 228)	7.4	PCI/L	FRANKLIN WATER UTILITY	24105631	Temporarily Abandoned	03/12/2014
RADIUM, (226 + 228)	7.1	PCI/L	SOUTH WAYNE WATERWORKS	13300771	Active	03/17/2015
RADIUM, (226 + 228)	13.2	PCI/L	VAN HANDELS MOBILE HM PK 2	44504229	Active	04/14/2014
RADIUM-226	9.4	PCI/L	VAN HANDELS MOBILE HM PK 2	44504229	Active	04/14/2014
RADIUM, (226 + 228)	6.03	PCI/L	CARRIAGE HILLS CONDOMINIUMS	26824061	Active	09/16/2015
RADIUM, (226 + 228)	7.29	PCI/L	DE PERE WATER DEPARTMENT	40504530	Active	12/02/2014

228)							
RADIUM-226	5.52	PCI/L	ASHWAUBENON WATERWORKS	40504563	Active		03/17/2014
RADIUM, (226 + 228)	14.16	PCI/L	BELLEVUE WATERWORKS	40504596	Active		04/15/2014
RADIUM-226	10.9	PCI/L	BELLEVUE WATERWORKS	40504596	Active		04/15/2014
RADIUM, (226 + 228)	6.36	PCI/L	BURLINGTON WATERWORKS	25201770	Active		02/10/2015
RADIUM, (226 + 228)	8.07	PCI/L	BURLINGTON WATERWORKS	25201770	Active		02/10/2015
RADIUM-226	6.38	PCI/L	BURLINGTON WATERWORKS	25201770	Active		04/01/2014
RADIUM-226	6.49	PCI/L	HOWARD WATERWORKS	40504684	Active		03/31/2014
RADIUM, (226 + 228)	6.51	PCI/L	ALLOUEZ WATERWORKS	40504552	Active		07/15/2014
RADIUM, (226 + 228)	6.9	PCI/L	ALMA WATERWORKS	60601926	Active		02/24/2015
RADIUM, (226 + 228)	6.7	PCI/L	BRANDON WATERWORKS	42004028	Active		06/24/2014
RADIUM, (226 + 228)	6.57	PCI/L	BROWNSVILLE WATERWORKS	11401390	Active		06/03/2015
RADIUM-226	6.15	PCI/L	BURLINGTON WATERWORKS	25201770	Active		02/10/2015
RADIUM-226	6.4	PCI/L	JOHNSON CREEK WATERWORKS	12801074	Active		03/12/2014
RADIUM, (226 + 228)	10.6	PCI/L	FREEDOM SANITARY DISTRICT	44516076	Active		06/17/2014
RADIUM-226	5.8	PCI/L	FREEDOM SANITARY DISTRICT	44516076	Active		06/17/2014
RADIUM, (226 + 228)	6.1	PCI/L	RAWHIDE YOUTH HOMES	46903219	Active		07/16/2015
RADIUM-226	6.37	PCI/L	FRANKLIN WATER UTILITY	24105631	Permanently Abandoned		03/12/2014

Source: Wisconsin Department of Natural Resources Drinking Water data. Test results downloaded by the Wisconsin Center for Investigative Journalism from Feb. 28, 2014 to Feb. 28, 2016.