

Portland Water District
FROM SEBAGO LAKE TO CASCO BAY

David Onos
Portland Public School System
Portland, ME

April 19, 2016

This letter is in response to your request for lead testing at 17 Portland public school facilities. Samples were collected following EPA Lead and Copper Rule sampling protocols. One (1) liter water samples were collected from 17 facilities on 3/29/16 and 3/30/16 and analyzed on 4/8/16 by EPA 200.5 inductively coupled plasma-optical emission spectroscopy. The PWD laboratory is certified for this method through the Maine Department of Health and Human Services. Please refer to the table on the following pages for your lead and copper results.

Your lead results are all below the EPA action level. The EPA action level for lead is 15 micrograms per liter ($\mu\text{g/L}$) and the maximum contaminant level goal (MCLG) is zero. Water coming into your facility does not contain lead. If present, lead originates from interior plumbing and fixtures.

With the exception of one sample (LYS-2) your copper results are below the EPA action level. The EPA action level for copper is 1.30 mg/L and the maximum contaminant level goal (MCLG) is also 1.30 mg/L.

For additional information on lead and copper in your drinking water please refer to the attached fact sheet and visit our website at <http://www.pwd.org/faqs>. If you have any questions about your results please reach us by email.

Sincerely,

Michael Koza
Regulatory and Security Advisor
Portland Water District
mkoza@pwd.org


The following definitions may be helpful in regard to the information provided above:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirement which a water system must follow.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.

Sample Address	Sample Location	PPS Identifier	Laboratory Identification Number	Copper Result (mg/L)	Lead Result (µg/L)
Reiche School 166 Brackett St. Portland	Kitchen	RCH-1	W-160329-0024	0.36	5.1
	1 st Floor next to greenhouse	RCH-2	W-160329-0025	0.88	5.0
King Middle School 92 Deering Ave. Portland	EWC near 107	KMS-1/ KNG-1	W-160329-0026	0.76	1.9
	EWC near 207	KMS-2	W-160329-0027	0.61	1.7
353 Cumberland Ave. Portland	Bayside Food service kitchen	353-1	W-160329-0028	0.13	0.90
	3 rd floor breakroom sink	353-2	W-160329-0029	0.39	1.1
Portland High School 284 Cumberland Ave. Portland	Bubbler near 130	PHS-1	W-160329-0030	0.25	<0.84
	Bubbler near 204	PHS-2	W-160329-0031	0.17	1.2
East End School 195 North St. Portland	Bubbler near 128	EE-1	W-160329-0032	0.23	<0.84
	Room 216 faucet	EE-2	W-160329-0033	0.27	1.1
Ocean Ave Elementary 150 Ocean Ave. Portland	EWC across from 113	OAES-1	W-160330-0020	0.25	<0.84
	EWC in cafeteria	OAES-2	W-160330-0021	0.31	<0.84
Lyseth Elementary 171 Auburn St. Portland	Bubbler across from gym	LYS-1	W-160330-0022	0.26	<0.84
	Room 21 faucet	LYS-2	W-160330-0023	1.4	1.7
Moore Middle School 171 Auburn St. Portland	Bubbler outside gym	MMS-1	W-160330-0024	0.34	<0.84
	EWC next to 159	MMS-2	W-160330-0025	0.22	1.8
Riverton Elementary 1600 Forest Ave. Portland	Room 302	RIV-1	W-160329-0034	0.57	1.5
	Room 401	RIV-2	W-160329-0035	0.47	2.0
Longfellow Elementary 432 Stevens Ave. Portland	Room 106	LNG-1	W-160329-0036	0.39	3.6
	EWC off gym	LNG-2	W-160329-0037	0.30	1.3
Lincoln Middle School 522 Stevens Ave. Portland	Water cooler in cafeteria	LMS-1	W-160329-0038	0.55	1.0
	Water cooler outside main office	LMS-2	W-160329-0039	0.48	<0.84
Deering High School 370 Stevens Ave. Portland	Ground floor water cooler	DHS-1	W-160329-0040	0.16	<0.84
	Water cooler in 126	DHS-2	W-160329-0041	0.17	0.90

Sample Address	Sample Location	PPS Identifier	Laboratory Identification Number	Copper Result (mg/L)	Lead Result (µg/L)
Peaks Island Elementary 4 Church Ave. Peaks Island	Room 2	PKS-1	W-160329-0042	0.63	7.0
	Kitchen faucet	PKS-2	W-160329-0043	0.82	8.0
Hall Elementary School 23 Orono Rd. Portland	Room 6 faucet	HLL-1	W-160329-0044	0.29	1.7
	EWC outside gym	HLL-2	W-160329-0045	0.20	1.3
Presumpscot Elementary 69 Presumpscot St. Portland	Teacher's lounge faucet	PRS-1	W-160329-0046	0.16	<0.84
	Room 13 faucet	PRS-2	W-160329-0047	0.56	2.6
PATHS 196 Allen Ave. Portland	112 kitchen faucet	PTH-1	W-160329-0048	0.71	13
	EWC outside 621	PTH-2	W-160329-0049	0.60	2.7
Waldron Way 92 Waldron Way Portland	Tilt skillet tap	WW-1	W-160329-0050	0.28	2.1
	Break room sink	WW-2	W-160329-0051	0.56	1.1



LEAD and COPPER in DRINKING WATER

Important Information on How to Protect Your Health

LEAD HEALTH EFFECTS

Lead is a common metal that has been in many consumer products but is now known to be harmful to human health if ingested or inhaled. It can be found in lead-based paint, air, soil, household dust, food, some types of pottery, and drinking water. Lead is rarely found in natural sources of water such as rivers and lakes or underground aquifers.

When people come in contact with lead, it may enter their bodies and accumulate over time, resulting in damage to the brain, nervous system, red blood cells, and kidneys. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities.

Lead in water can be a special problem for infants whose diets may be mostly fluids, such as baby formula or concentrated juices mixed with water. Smaller bodies can absorb lead more rapidly than bigger ones, so amounts of lead that won't hurt an adult can be very harmful to a child. Adults who drink this water over many years could develop kidney problems or high blood pressure.

COPPER HEALTH EFFECTS

Copper is a reddish metal that occurs naturally in rock, soil, water, sediment, and air. It has many practical uses in our society and is commonly found in coins, electrical wiring, and pipes. It is an essential element for living organisms, including humans and, in small amounts, necessary in our diet to ensure good health. However, some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience adverse health effects including vomiting, diarrhea, stomach cramps, and nausea. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage.

The human body has a natural mechanism for maintaining the proper level of copper in it. However, children under 1 year old have not yet developed this mechanism and, as a result, are more vulnerable to the toxic effects of copper. People with Wilson's disease also have a problem with maintaining the proper balance and should also exercise particular care in limiting exposure to copper. People with Wilson's disease should consult their physicians.

HOW TO REDUCE YOUR EXPOSURE

Lead may work its way into drinking water after the water has left the treatment plant and is on its way to people's faucets. This usually happens through the corrosion of materials containing lead in household plumbing. These materials include brass faucets, lead solder on copper pipes, lead pipes or lead service lines connecting the water main to the inside plumbing. Lead pipes are no longer installed for service lines or in household plumbing, and lead solder has been outlawed in Maine since 1987.

The amount of lead allowed in brass faucets has also been limited, but can still contribute some lead to drinking water (note that many faucets are made of brass even if they do not have a "brass" color). Even with these restrictions in place, some homes-especially older homes-may still have significant amounts of lead in their plumbing systems.

Copper works its way into the water by dissolving from copper pipes in the household plumbing. The longer the water has stood idle in the pipes the more copper is likely to have absorbed. Newer homes with copper pipes may be more likely to have a problem. Over time, a coating forms on the inside of the pipes and can insulate the water from the copper in the pipes. In newer homes, this coating has not yet had a chance to develop. Thus, anytime the water has not been used for more than 6 hours – overnight, for example, or during the day when people are gone to work or school – it should be cleared from the pipes before being used for drinking or cooking.

Let the cold water faucet run until you can feel the water getting colder, usually 30 – 60 seconds. The amount of time it takes will depend on your home and how its plumbing is arranged.

Other Household water uses will also help clear standing water from the homes plumbing. For example, you may want to establish a routine of doing household tasks that use water – such as showering, flushing the toilet, or running the dishwasher – first thing in the morning before using water for drinking or cooking. Keep in mind that you'll still need to flush individual faucets for a short time before using them for drinking water.

Hot water dissolves lead/copper more quickly than cold water so don't use water from your hot water faucet for cooking or drinking. If you need hot water for cooking or drinking, take water from the cold tap and heat it. It is especially important not to use the hot water for making baby formula.

Some treatment devices can reduce the amount of lead in your drinking water. Reverse-osmosis and distillation units can be used for that purpose. A few types of water filters also remove lead and copper. Check the product literature to be sure it has been certified for metals removal by NSF International (<http://nsf.org>). Also, you must follow the manufacturers recommendations for operation and maintenance to ensure that the treatment equipment works correctly.

The water you run from drinking water taps does not have to be wasted. You can use this water for cleaning purposes or for watering plants. You may want to keep a container of drinking water in your refrigerator, so you don't have to run water every time you need it.

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>3-28-16</u>	Date <u>11:00 PM</u>
Sample was collected:	Time <u>3-29-16</u>	Date <u>6:30 AM</u>

I have read the above directions and have taken a tap sample in accordance with the directions.



Signature

3-29-16
Date

353 CUMBERLAND AVE / 2B PORTLAND
353-1 3RD FLOOR KITCHEN FAUCET
Address

PH 27 HND

Please do not write in this space - Laboratory use only

Received by: <u></u>	Date/Time: <u>4/1/16 09:11</u>
Relinquished by above	Date/Time: _____
Received by lab:	Date/Time: _____
Work order #: <u>300510</u>	Sample ID#: <u>W-160221-0028</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>3-28-16</u>	Date <u>6:00 PM</u>
Sample was collected:	Time <u>3-29-16</u>	Date <u>6:35 AM</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

D
Signature

3-29-16
Date

353 CUMBERLAND / 28 PORTLAND ST
353-2 - 1ST FLOOR SERVING KITCHEN FAUCET

Address

Please do not write in this space - Laboratory use only

Received by: <u>[Signature]</u>	Date / Time: <u>4/1/16 11:21 AM</u>
Relinquished by above	<u>[Signature]</u>
Received by lab:	Date / Time:
Work order # <u>360411</u>	Sample ID# <u>WS160329-0029</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00pm</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:05 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

<u><i>David M. [Signature]</i></u>	<u>3-29-16</u>
Signature	Date

DEARING HIGH SCHOOL
GROUND FUR EWC DHS-1
Address

PH 2 KING

Please do not write in this space. Laboratory use only.

Received by: <u>M</u>	Date/Time: <u>4/1/16 02:00</u>
Relinquished by above	Date/Time:
Received by lab	Date/Time:
Work order #: <u>360410</u>	Sample ID: <u>W160321-0040</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00pm</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:00pm</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Healey
Signature
DEERING HIGH SCHOOL
EWG IN RM 126 DHS-2
Address

3-29-16
Date

PHLL HND

Please do not write in this space. Laboratory use only.

Received by: <u>MA</u>	Date/Time: <u>4/1/16 0901</u>
Relinquished by above:	Date/Time:
Received by lab:	Date/Time:
Work order #: <u>360410</u>	Sample ID# <u>AW 160329-004</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>7:00 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

[Signature]
 Signature
 EAST END ELEMENTARY
 EE-1 - BUBBLER NEAR 12B

3-29-16
 Date

Address

Please do not write in this space. Laboratory use only.

Received by: <u>[Signature]</u>	Date/Time: <u>3/29/16 10:00</u>
Requisitioned by: <u>[Signature]</u>	Date/Time: _____
Received by: _____	Date/Time: _____
Work order: <u>5620917</u>	Sample ID: <u>W-100327-0034</u>

PH 12 HNB

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 Pm</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>7:10 Am</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

[Signature]
 Signature
EAST END ELEMENTARY
EE-2 Room 216 FAUCET
 Address

3-29-16
 Date

PH 42 HNB

Please do not write in this space. Laboratory use only.

Received by: <u>[Signature]</u>	Date / Time: <u>4/1/16 0900</u>
Relinquished by above	Date / Time:
Received by lab:	Date / Time:
Work order #: <u>312049</u>	Sample ID#: <u>WV4160329-0055</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St, Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 Pm</u>	Date <u>3-28</u>
Sample was collected:	Time <u>7:00 AM</u>	Date <u>3-29</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Gentry
Signature
Hall School - Rm 6
HLL 1

3-29-16
Date

Address

Please do not write in this space (laboratory use only)

Received by: PH Date/Time: 4/1/16 02:14

Relinquished by above:

Received by lab: _____ Date/Time: _____

Work order # 31607108 Sample ID# W-16032910044

PH 22 MVE

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 pm</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>7:05 am</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Sweeney 3-29-16
 Signature Date

HALL ELEMENTARY
RWC OUTSIDE GYM HLL-2

Address PH 62 HND

Please do not write in this space. Laboratory use only.

Received by: <u>[Signature]</u>	Date / Time: <u>4/1/16 0900</u>
Relinquished by above	
Received by lab	Date / Time
Work order # <u>365369</u>	Sample ID# <u>W-165329-6695</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:20 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

[Signature]
Signature

3-29-16
Date

KING MIDDLE SCHOOL
KMS 1 WATER COOLER NEAR 107
Address

PH 12 HAN

Please do not write in this area - Laboratory use only

Received by: <u>[Signature]</u>	Date/Time: <u>4/1/16 10:40</u>
Relinquished by: <u>[Signature]</u>	Date/Time: _____
Work order #: <u>3120413</u>	Sample ID#: <u>WA160329-0030</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:25 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

[Signature]
Signature

3-29-16
Date

KING MIDDLE SCHOOL
KMS 2 - WATER COOLER MAR 2017

Address

Please do not write in this space - Laboratory use only

Received by: <u>[Signature]</u>	Date/Time: <u>4/1/16 PM</u>
Relinquished by above	Date/Time:
Received by lab:	Date/Time:
Work order # <u>3120413</u>	Sample ID# <u>WV160329-0021</u>

PH 2 HNR

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:45 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Shugart
 Signature
 LINCOLN MIDDLE SCHOOL
 CAFE EWC LMS-1
 Address

3-29-16
 Date

PH 22 MNR

Please do not write in this space. Laboratory use only.

Received by <u>M</u>	Date/Time <u>4/11/16 09:00</u>
Relinquished by Above	Date/Time _____
Received by Lab _____	Sample ID# <u>WV 165329-0038</u>
Work order # <u>3069 4102</u>	

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:50 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Seery
Signature

3-29-16
Date

LINCOLN MIDDLE SCHOOL
EWC NEAR MAIN OFFICE

LMS-2

Address

PH 2 MNR

Please do not write in this space. Laboratory use only.

Received by: <u>M</u>	Date / Time: <u>4/1/16 0300</u>
Requisitioned by above	Date / Time:
Received by lab:	Date / Time:
Work order # <u>360902</u>	Sample ID# <u>WV160329-0039</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used: Time 10:00 pm Date 3-28-16
Sample was collected: Time 6:30 AM Date 3-29-16

I have read the above directions and have taken a tap sample in accordance with the directions.

Signature David M. Gray Date 3-29-16
LONGFELLOW ELEMENTARY LNG 1
Room 106

Address

Please do not write in this space. Laboratory use only.

Received by: W Date/Time: 4/1/16 09:09

Relinquished by above: _____ Date/Time: _____

Received by lab: _____

Work order #: 3170103 Sample ID#: WVX0029-0039

PH 42 ANG

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:25 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Blaney
Signature

3-29-16
Date

LONGFELLOW ELEMENTARY LNG-2
WATER FOUNTAIN OFF GYM
Address

PH 2 HAND

Please do not write in this space - Laboratory use only

Received by: <u>[Signature]</u>	Date/Time: <u>4/1/16 10:10</u>
Relinquished by above	Date/Time:
Received by lab:	Date/Time:
Work order # <u>560405</u>	Sample ID# <u>WV100379</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>9:00 pm</u>	Date <u>3-29-16</u>
Sample was collected:	Time <u>6:50 am</u>	Date <u>3-30-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. King
Signature

3-30-16
Date

LYSIAH ELEMESTARY
BUBBLE ACROSS FROM 64m

LYS-1

Address

PH 22 HNR

Please do not write in this space. Laboratory use only.

Received by: <u>PH</u>	Date/Time: <u>3/30/16 09:00</u>
Relinquished by above:	Date/Time:
Received by lab:	Date/Time:
Work order # <u>306-1111</u> <u>306-1111</u>	Sample ID: <u>W-160350-0622</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

* see M. Koza email for correct dates:

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:

Time 10:00 PM

Date

^{rss 4/1/16}
~~3-19-16~~

3/29/16

Sample was collected:

Time 6:55 AM

Date

^{rss 4/1/16}
~~3-20-16~~

3/30/16

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Gandy
Signature

LYS-2

Date

^{rss 4/1/16}
~~3-20-16~~

3/30/16

LYSETH ELEMENTARY

Rm 21 FAUCET

Address

PH 2 HND

Please do not write in this space - Laboratory Property

Received by: MA Date/Time: 4/1/16 09:00

Repackaged by: above

Received by: lab Date/Time: _____

Work order #: 201604030014 Sample ID#: WI-160330-0030

^{rss 4/1/16}

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-29-16</u>
Sample was collected:	Time <u>6:40</u>	Date <u>3-30-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Green
 Signature
 MODRLE MIDDLE SCHOOL
 BUBBLER OUTSIDE GYM
 MMS-1

3-30-16
 Date

Address *PH 12 HNE*

Please do not write in this space. Laboratory use only.	
Received by: <u>NA</u>	Date/Time: <u>4/1/16 0900</u>
Requisitioned by: <u>NA</u>	Date/Time: <u>NA</u>
Work order #: <u>360-414</u>	Sample ID#: <u>W1160326 10024</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 pm</u>	Date <u>3-29-16</u>
Sample was collected:	Time <u>6:35 AM</u>	Date <u>3-30-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Searcy
 Signature
 MOORE MIDDLE SCHOOL mms-2
 EWC NEXT TO 159
 Address

3-30-16
 Date

PH 52 HNRJ

Please do not write in this space. Laboratory use only.

Received by: *AD* Date/Time *4/1/16 0261*

Relinquished by above

Received by lab: _____ Date/Time _____

Work order # *2016-0119* Sample ID# *W160390-0023*

15-011116

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-29-16</u>
Sample was collected:	Time <u>6:15 AM</u>	Date <u>3-30-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Lewis
Signature

EW C ACROSS FROM 113
OCEAN AVE ELEMENTARY OAES I
Address

3-30-16
Date

pH < 2 HNO3

Please do not write in this space. Laboratory use only.

Received by: <u>M</u>	Date/Time: <u>4/1/16 09:41</u>
Relinquished by above	Date/Time:
Requested by lab	Date/Time:
Work order # <u>3061406</u>	Sample ID# <u>W.100330-0030</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 pm</u>	Date <u>3-29-16</u>
Sample was collected:	Time <u>6:10 AM</u>	Date <u>3-30-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

David M. Gray
Signature

3-30-16
Date

OCEAN AVE ELEMENTARY OAES-2
EWIC IN CAFETERIA

Address

PH 12 HND

Please do not write in this space - Laboratory use only.

Received by: <u>PA</u>	Date/Time: <u>4/1/16 09:11</u>
Relinquished by above:	Date/Time:
Received by lab:	Date/Time:
Work order # <u>3100101</u>	Sample ID# <u>W-110330-001</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>9:00 P.M.</u>	Date <u>3/28/16</u>
Sample was collected:	Time <u>5:50 A.M.</u>	Date <u>3/29/16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

Steven A. Thom
Signature

3/29/16
Date

196 Allen Ave. Port. Me.
Address RM 112 Kitchen

PTH 1

pH 2.14

Place do not write in this space - Laboratory use only

Received by: <u>ML</u>	Date/Time: <u>4/1/16 09:00</u>
Relinquished by above:	Date/Time:
Received by lab:	Date/Time:
Work order #: <u>310504</u>	Sample ID# <u>W 100327-0045</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>9:00 PM,</u>	Date <u>3/28/16</u>
Sample was collected:	Time <u>6:05 AM</u>	Date <u>3/29/16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

Steve A. Jones PTH 2 3/29/16
 Signature _____ Date _____
 EWC OUTSIDE 621

196 Mellen Ave Portland, Me.
 Address _____

PH 42 HND

Place each on white card in space - Laboratory use only	
Received by: <u>PH</u>	Date/Time: <u>3/29/16 9:00</u>
Relinquished by above:	Date/Time:
Received by lab:	Date/Time:
Work order #: <u>600054</u>	Sample ID#: <u>W-1160227-0089</u>

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom col. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bc faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample this time to ensure that all information contained on the label is correct. Complete the informat bottom of this form and return the form and full sample bottle to the location where it was picked
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instraict
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AT ANY PWD WATER SERVICE OFFICE.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used: Time 4 PM Date 3/29/16
 Sample was collected: Time 8:23 AM Date 3/29/16

I have read the above directions and have taken a tap sample in accordance with the directions.

Signature [Signature] Date 3/29/16
PKS 1 Room 2
PEAKS ISLAND SCHOOL
 Address 4 Church St P.I. ME 04118

PH < 2 HAND

Please do not write in this space. Use this space for US-Only

Received by: PH

Received by above

Received by lab:

Work order # 360-117

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>6:30pm</u>	Date <u>3/28/16</u>
Sample was collected:	Time <u>8:30am</u>	Date <u>3/29/16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

Signature A. Volk Date 3/29/16
PKS 2 PEAKS ISLAND SCHOOL
4 CHURCH ST P.I. ME OAKS KITCHEN SINK
 Address PKS 2 WVA

Please do not write in this space - label only

Received by <u>PA</u>	Date/Time <u>4/1/16</u>
Relinquished by above	Date/Time
Received by lab	Date/Time
Work order # <u>212-414</u>	Sample ID# <u>WV-160329-0043</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:


1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Siros at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>11:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:45 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.


 Signature
PORTLAND HIGH SCHOOL PHS-1

3-29-16
 Date

WATER BUBBLER NEAR 130
 Address

Please do not write in this space. Laboratory use only.

Received by: <u>PA</u>	Date / Time: <u>3/29/16 0900</u>
Retrieved by above	
Received by lab:	Date / Time:
Work order #: <u>3400 SAZ</u>	Sample ID#: <u>WV0329-0030</u>

PH < 2 HNR

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>11:00 pm</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:50 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

D
 Signature
 PORTLAND HIGH SCHOOL
 PHS-2 BUBBLER NAR 204

3-29-16
 Date
 PH 2
 HND

Address

Please do not write in this space. Laboratory use only.

Received by: <u>M</u>	Date/Time: <u>4/1/16 09:17</u>
Relinquished by above	Date/Time: _____
Received by lab	Date/Time: _____
Work order #: <u>3605112</u>	Sample ID#: <u>WV1126327-0031</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:


1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>7:15 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

 3-29-16
 Signature Date
PREMPSHOT ELEMENTARY
PRS-1 TEACHER'S LOUNGE FAUCET
 Address PH 22 HND

Please do not write in this space. Laboratory use only.

Received by: <u>PK</u>	Date/Time: <u>4/1/16 0:00</u>
Relinquished by above	Date/Time:
Received by lab:	Date/Time:
Work order #: <u>300415</u>	Sample ID #: <u>WV160529-0046</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:


1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 Pm</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>7:20 Am</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.



 Signature
 PRESUMPTCOT ELEMENTARY SCHOOL
 PRS-2 ROOM 13 FAUCET

3-29-16
 Date

Address

PH 22 HNR

Please do not write in this space. Laboratory use only.

Received by:  Date/Time: 4/1/16 0900

Relinquished by above: _____ Date/Time: _____

Received by lab: _____ Date/Time: _____

Work order #: 308915 Sample ID#: W-160327-0097

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>6:00 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

[Signature] _____ Date 3-29-16

Signature PORTLAND SCHOOLS
REICHE SCHOOL KITCHEN FAUCET RCH I

Address _____

Please do not write in this space. Laboratory use only.

Received by: [Signature] Date/Time: 4/1/16 09:11

Relinquished by above: _____ Date/Time: _____

Received by lab: _____

Work order #: 31204116 Sample ID#: W-160329-0024

PH 22 HND

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:


- 1: After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:50 Pm</u>	Date <u>3-28</u>
Sample was collected:	Time <u>6:05 Am</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

 3-29-16
 Signature Date

REICHE SCHOOL RCH-2 WATER COOLER NEAR GREENHOUSE
PORTLAND SCHOOLS 1ST FLOOR
 Address

Please don't write in this space - Laboratory use only

Received by <u>DR</u>	Date/Time <u>3/29/16 9:00</u>
Relinquished by above	
Received by lab	Date/Time
Work order <u>2160116</u>	Sample ID <u>W10032920025</u>

PH 2 HNB

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirosi at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used: Time 10:00 pm Date 3-28-16
Sample was collected: Time 7:35 am Date 3-29-16

I have read the above directions and have taken a tap sample in accordance with the directions.

Deirdre M. Gray
Signature
RIVERTON ELEMENTARY
Room 302 RIV-1
Address

3-29-16
Date

PH 2 HNR

Please do not write in this space. Laboratory use only.

Received by: <u>M</u>	Date / Time: <u>4/1/16 09:00</u>
Reiminished by above	Date / Time:
Received by lab:	
Work order # <u>360806</u>	Sample ID # <u>160329-0034</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>10:00 PM</u>	Date <u>3-28-16</u>
Sample was collected:	Time <u>7:30 AM</u>	Date <u>3-29-16</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

Daniel McGray
 Signature
RIVERTON ELEMENTARY RIV 2
Room 401

3-29-16
 Date

Address

PH 22 HND

Please do not write in this space - Laboratory use only

Received by: MA Date/Time: 4/1/16 12:01

Relinquished by above: _____ Date/Time: _____

Received by lab: _____ Date/Time: _____

Work order # 3-29-16-5 Sample ID# WA 160329-0035

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:	Time <u>5:00 pm</u>	Date <u>3/28</u>
Sample was collected:	Time <u>5:00 am</u>	Date <u>3/29</u>

I have read the above directions and have taken a tap sample in accordance with the directions.

Signature [Handwritten Signature]
TILT SKILLET TAP

Date 3/29/16

Address 92 Waldron Way

WW-1

pH 12 HNDP

Please do not write in this space (laboratory use only)

Received by: <u>[Signature]</u>	Date/Time: <u>3/29/16 10:00</u>
Relinquished by: Above	Date/Time: _____
Received by: Lab	Date/Time: _____
Work order #: <u>20160104</u>	Sample ID: <u>WV160329-0050</u>

Dear Homeowner:

Please use the following instructions to properly collect a lead sample from your home.

Use the enclosed 1 liter plastic bottle to collect your water sample. The sample is to be collected after the water has remained motionless in the pipes for at least six hours. The collection procedure is described below.

Directions for collecting water sample for lead and copper analysis:

1. After at least 6 hours of non-usage, collect the sample from the kitchen or bathroom cold-water faucet. **DO NOT RUN WATER BEFORE COLLECTING SAMPLE.** Place the open sample bottle below the faucet and gently open the cold water tap, filling the bottle.
2. Tightly cap the sample bottle and place in the sample bag provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct. Complete the information on the bottom of this form and return the form and full sample bottle to the location where it was picked up.
3. The results of the analyses will be mailed to you within 30 days of analysis completion. Call Rebekah Sirois at 774-5961 x3658 or Susan Jasper x3827 if you have any questions regarding these instructions.
4. (Please drop off Sample at PWD Customer Service 225 Douglass St. Portland Thank You.)
Hours: 8:30am to 4:30pm Monday - Friday

PLEASE NOTE: THIS SAMPLE CAN BE COLLECTED AFTER ANY 6 HOUR NON-USAGE PERIOD.

TO BE COMPLETED BY RESIDENT AND RETURNED WITH SAMPLE

Water was last used:

Time 5:00 pm

Date 3/28/16


Sample was collected:

Time 5:10 am

Date 3/28/16

I have read the above directions and have taken a tap sample in accordance with the directions.

Signature



Date

3/28/16

BREAK ROOM SINK WW-2

92 Walden Way

Address

PH 22 HN 12

Please do not write in this space - Laboratory use only.

Received by: <u>PK</u>	Date / Time: <u>4/1/16 0900</u>
Relinquished by: above	Date / Time:
Received by: lab	Date / Time:
Work order #: <u>0120402</u>	Sample ID#: <u>WL160327-0051</u>

